

WATKINS HIRE LIMITED

STEAM BOILER PLANT

Free phone 0500 526696

Hire ♦ Sales ♦ Repairs ♦ Installation ♦ Annual inspections

WATKINS HIRE LOG OF DAILY AND WEEKLY TESTING OF WATER GAUGES AND SAFETY CONTROLS

	DATE																															
MONTH	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Water gauges tested																																
Level indicated RH Glass																																
Level indicated LH Glass																																
Automatic water level control test																																
Feed pump working																																
Firing stopped																																
Alarm sounded																																
Independent low water-alarm tested																																
Firing stopped and locked out																																
Alarm sounded																																
Tested at (Time)																																
Left in order at (Time)																																
Boiler pressure gauge reading																																
Tested by (Signature)																																
Observations Oil Level																																

NOTES: 1. To be completed by Boiler attendant(s) or person(s) responsible for safe working. 2. Tick squares to indicate daily tests completed satisfactorily